



Plan View
Scale - 1 : 250



Description	Symbol	Avg	Max	Min	Max/Min	Avg/Min
Egress - South	+	50.1 lux	123.4 lux	10.2 lux	12.1:1	4.9:1
Entrance - East Tower Pedestrian Entry	+	111.7 lux	121.8 lux	101.6 lux	1.2:1	1.1:1
Entrance - North Amenity	+	91.9 lux	113.3 lux	52.0 lux	2.2:1	1.8:1
Entrance - Podium Lobby	+	116.7 lux	120.8 lux	112.5 lux	1.1:1	1.0:1
Entrance - West Tower Entry	+	106.7 lux	116.7 lux	96.7 lux	1.2:1	1.1:1
North Drive Aisle	+	21.9 lux	114.8 lux	7.6 lux	15.1:1	2.9:1
Property Line - North (Adjacent Building)	+	1.1 lux	3.3 lux	0.0 lux	N/A	N/A
Property Line - South/East - Grenoble/Deauville Road	+	5.3 lux	23.7 lux	0.0 lux	N/A	N/A
Property Line - West (Parkland Dedication Facing)	+	1.0 lux	5.2 lux	0.0 lux	N/A	N/A
Landscape Area - North Courtyard Area	+	16.7 lux	33.6 lux	2.5 lux	13.4:1	6.7:1
Landscape Area - South Entrance Area	+	22.7 lux	55.1 lux	0.0 lux	N/A	N/A
Curb - South/East - Grenoble/Deauville	+	1.8 lux	7.2 lux	0.1 lux	72.0:1	18.0:1
Landscape Area - East Walkway	+	13.2 lux	69.0 lux	0.1 lux	690.0:1	132.0:1
Landscape Area - Northwest Walkway	+	57.1 lux	136.9 lux	24.3 lux	5.6:1	2.3:1

Symbol	Label	Image	Quantity	Manufacturer	Catalog Number	Description	Number Lamps	Lumens Per Lamp	Light Loss Factor	Wattage
○	L1		34	Insight Lighting	SSL/MO/RGBW/40°		1	858	0.82	33.46
—	L2		6	AXIS LIGHTING INC.	WBSLED-700-35-SO-4	AXIS LIGHTING WET BEAM DIRECT LED LUMINAIRE	1	2799	0.82	31.06
□	LS1		11	Selux Corporation	ACL-RSR-X-5G1530-30-XX-UNV	Gray formed aluminum housing, clear/frosted plastic optics	1	3522	0.82	36
□	LS1A		0	Selux Corporation	ACL-R1-X-5G1530-30-XX-UNV-HS	Gray formed aluminum housing, clear/frosted plastic optics	1	2460	0.82	36
□	LS2		3	Selux Corporation	ACL-R2-X-5G1800-30-XX-UNV-HS	Gray formed aluminum housing, clear/frosted plastic optics	1	3424	0.82	54
□	LS3		6	Generation Brands	7000BSTR425C1UNV30 C	LED BOLLARD	1	1254	0.82	19.4